

Figure 3-1 is a drawing of the standard temporary overhead service installation recommended by PUD. The specifications given are the minimum acceptable. Do not deviate from the installation standards without approval from your PUD Area Designer.

The service conductor shall be coded and the neutral conductor shall be identified by the color white or light gray.

Items owned and installed by the customer:

1. 4" x 4" x 14' minimum, continuous, single structure
2. Meter socket and distribution panel
3. Ground wire (per NEC)
4. Ground rods (per NEC)
5. 2" x 4" bracing (2 required)
6. Service entrance conductors (18" out of the weatherhead)
7. Insulator spool

Items owned and installed by the PUD:

1. Service Line
2. Meter

FIGURE 3-1

